



UNIVERSITY OF SOUTH CAROLINA

AMENDMENT NO. 1 TO SOLICITATION

DATE: June 10, 2016
TO: ALL VENDORS
FROM: Juaquana Brookins, Procurement Officer
SUBJECT: USC-RFQ-2983-JB, Strom Thurmond Wellness & Fitness Center Interior Signage Package

Amendment No.1 modifies the Requests for Quotes only in the manner and to the extent as stated herein.

Vendor Questions and Answers

OFFERORS SHALL ACKNOWLEDGE RECEIPT OF AMENDMENT NO. 1 IN THE SPACE PROVIDED BELOW AND RETURN IT WITH THEIR BID RESPONSE. FAILURE TO DO SO MAY SUBJECT BID TO REJECTION.

Authorized Signature

Name of Offeror

Date

Q & A

1. The signs are designed with proprietary system called Imago. Will an alternative be accepted if it functions the same and looks similar? **Yes. The alternative must be submitted for approval at least 2-3 days prior to submission deadline.**
2. In the detail on page 1.0, at the bottom of the face, labeled "F", a satin finished aluminum extrusion. On the edge view, it's labeled "G" which is 1 3/4" x 1 3/4" diameter magnet, which makes it sound as if it is round. I'm not seeing it in the detail, or I am misunderstanding something. **The shape of the magnet does not matter. There is a cap on the end of the extrusion which covers it, the end is not visible. It is only there to help affix/align the modules that are placed below the base sign.**