



**WATERPROOFING – EAST RAMPS/ZONE SEATING AREA
WILLIAMS BRICE STADIUM
UNIVERSITY OF SOUTH CAROLINA
PROJECT NO: H27-Z297**

**Addendum Two
September 12, 2016**

This addendum modifies the Contract Documents only in the manner and to the extent stated herein and shown on any accompanying drawings and will become a part of the Contract Documents. Except as specified or otherwise indicated by this addendum, all work shall be in accordance with the basic requirements of the Contract Documents.

GENERAL:

1. Attached is the *sign-in sheet* for the Pre-Bid meeting held Wednesday, September 07, 2016, indicating all attendees.
2. Per the Pre-Bid Meeting on September 07, all questions regarding this project were to be submitted in writing to the architect no later than 6:00pm on Wednesday, September 14, 2016. Email acceptable.
The architect's email address: Keith Myhand: kmyhand@jcsarchitects.com
3. USC will assume the cost of abatement of any hazardous materials – bidders should not include any abatement costs in their bids.
4. All inspections will be provided by the owner.
5. Location of contractor dumpster(s) will be coordinated with the owner as space and locations are limited during the football season. On weeks when there is a Saturday football game, the construction dumpster must be removed from the stadium property no later than 12 noon on Friday.
6. On weeks when there is a Saturday football game, Contractor should have jobsite completely clean and secured and leave the jobsite by 12 noon on Friday. If block walls are not constructed high enough to act as a barrier, contractor to install temporary 6' high fencing panels with green windscreen around work area for game events.

Home game schedule potentially relevant to this work is as follows:

Saturday, 10/8, vs Georgia
Saturday, 10/22, vs Massachusetts
Saturday, 10/29, vs Tennessee
Saturday, 11/5, vs Missouri
Saturday, 11/19, vs Western Carolina

7. The interior and end ramps can be used for standard pick-up truck traffic and trucks with open trailers with materials – there are height restrictions on the end ramps. Any loads with excessive weight or any large pieces of equipment will need to be vetted thru the structural engineer prior to placing on the ramps.
8. A nearby offsite staging area will be made available as needed when coordinated in advance with the owner.
9. Alternate #2 - If the Owner accepts this Alternate for the Family Toilet on the west upper deck, the sewer line tie-in for that scope will be deferred until after 11/19 as it involves work in an executive club area used during home games.
10. The owner will designate a nearby restroom onsite for the contractor's use. The contractor is to leave the restroom as clean as he found it upon project completion.

DRAWINGS:

1. Sheet A201.1, Detail 3: Change the chase dimension from 1'-4" to 1'-8" minimum to allow for a 12" clear chase. Due to an existing metal conduit at the corner of the left side concrete bent, the rear wall will need to be located closer to the lower concrete panel which will result in a larger chase. Confirm actual location in field with architect.
2. Sheet A203.2, Details 2 & 3: Change the chase dimension from 1'-4" to 1'-8" to allow for a 12" clear chase.
3. Sheet E201: In Electrical Symbol Legend, change lighting fixture catalog number from Lithonia "XWL232MV" to Lithonia "DMW232MV". (This will provide a true wet location fixture with a wall mounting application).

END OF ADDENDUM

**University of South Carolina
Non Mandatory Pre Bid Sign In Sheet**
Columbia, SC

Project Name: Williams Brice Stadium-Family/ADA Toilet Renovation
Project Number: H27-Z297
Pre Bid Date & Time: Wednesday, September 7, 2016 11AM 743 Greene St; Conf Rm 053; Cola, SC 29208

SWMBE Contractor Indicate Below	Name	Company Name	Address	Phone #	Email
S W M B E	Rando Motley	MAR		803-556-3432	
S W M B E	Jeff Paschal	MAR	141 Riverchase Way Lexington SC 29072	803-796-8960	JEFFP@MARCONSTRUCTION.COM
S W M B E	Awn Meace	First Class Construction	126 Suber Rd. Cola, SC 29210	(803) 926-1922	awnace@fcon.com
S W M B E	KEITH MYHAND	JCS	412 MEETHGS ST. WEST COLA, SC 29169	803-791-1020	KMYHAND@JCSARCHITECTS.COM
S W M B E	BRETT WICKS	MSI	745 GREENWOOD RD WEST COLUMBIA 29169	803-796-3324	BRETTWICKS@MSICONST.COM
S W M B E	Chris Randell	Pioneer	120 Cessna Dr. Tranton SC 29847	803-663-7778	crandall@pioneeremc.com
S W M B E	Chris Page	"			
S W M B E					
S W M B E					

****By signing this sheet you agree to receive information electronically.

**University of South Carolina
Non Mandatory Pre Bid Sign In Sheet**
Columbia, SC

Project Name: Williams Brice Stadium-Family/ADA Toilet Renovation
Project Number: H27-Z297
Pre Bid Date & Time: Wednesday, September 7, 2016 11AM 743 Greene St; Conf Rm 053; Cola, SC 29208

SWMBE Contractor Indicate Below	Name	Company Name	Address	Phone #	Email
S W M B E	Albert Benitez	Mauricio	701 Nora Ln. Mt Pleasant SC	843-906-1261	a-benitez@contractman.com
S W M B E	Mike Sweatt	AOS	1224 two notch rd	803-798-6831	MIKE@AOSSC.ORG
S W M B E	CHRIS SEINAR	PennContracting	P.O. BOX 204 Ballentine, SC 29002	803-407-9724 F-803-781-4142	BOB@PENCONTRACTING.COM
S W M B E	Aimee Rish	USC Facilities Procurement	743 Greene St 29208	803-777-2264	arish@fms.usc.edu
S W M B E	Ann Derrick	Facilities	743 Greene St	777-5811	
S W M B E					
S W M B E					
S W M B E					
S W M B E					

****By signing this sheet you agree to receive information electronically.