

SECTION 00 9113 - ADDENDUM NUMBER 3

PARTICULARS

1.01 DATE: SEPTEMBER 23, 2016

1.02 PROJECT: GENERAL CONSTRUCTION INDEFINITE DELIVERY CONTRACT (MCKISSICK MUSEUM BATHROOM RENOVATIONS)

1.03 OWNER'S PROJECT NUMBER: H27-D259-CB

1.04 OWNER : UNIVERSITY OF SOUTH CAROLINA

1.05 ARCHITECT : GMK ASSOCIATES

TO: PROSPECTIVE BIDDERS :

2.01 THIS ADDENDUM FORMS A PART OF THE CONTRACT DOCUMENTS AND MODIFIES THE ORIGINAL PROCUREMENT DOCUMENTS DATED JULY 25, 2016, AND ADDENDUM NUMBER 1 ISSUED SEPTEMBER 16, 2016 , AND ADDENDUM NUMBER 2 ISSUED SEPTEMBER 22, 2016, WITH AMENDMENTS AND ADDITIONS NOTED BELOW.

2.02 ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED IN THE BID FORM . FAILURE TO DO SO MAY DISQUALIFY THE BIDDER.

2.03 THIS ADDENDUM CONSISTS OF 1 PAGE:

CHANGES TO THE DRAWINGS:

4.01 DRAWING P0.0 - PLUMBING SCHEDULES, NOTES, LEGENDS, DETAILS, AND ABBREVIATIONS

- A. Fixture L1A - The faucet selected is only available as a pop-up style fixture and should be installed without the pop-up. The lavatory should be installed with a grid strainer and be under-mount as shown in the picture on sheet P0.0. The correct model number for this lavatory is K-2214.
- B. Fixture L2A - The faucet selected is only available as a pop-up style fixture and should be installed without the pop-up. The lavatory should be installed with a grid strainer.
 - 1. The discontinued sink is the only fixture we could find that was similar to the sink requested by the owner. We have however found it in on-line stores such as Wayfair, Amazon and Faucetdirect.

END OF ADDENDUM NUMBER 3