



AMENDMENT NO. 1 TO SOLICITATION

DATE: February 21, 2017
TO: ALL VENDORS
FROM: Tracy Fountain
SUBJECT: USC-RFQ-3100-TF
DESCRIPTION: Furnish and Deliver Power Cable and THHN Copper Cable

This Amendment No. 1 modifies the Request for Quotes only in the manner and to the extent as stated herein.

Item #1 Question from Vendors and Answer from USC in Red

1. I reached out to plonked and they have asked whether this is for tray cable use or non cable tray use. Please advise.

Please refer to the SCOPE OF WORK / SPECIFICATIONS on Page 8 of the Quote. It states that it is an EPR jacket. 133% insulation The cable specified can go both places.

OFFERORS SHALL ACKNOWLEDGE RECEIPT OF AMENDMENT NO. 1 IN THE SPACE PROVIDED BELOW AND RETURN IT WITH THEIR QUOTE RESPONSE. FAILURE TO DO SO MAY SUBJECT QUOTE TO REJECTION.

Authorized Signature

Name of Offeror

Date