



UNIVERSITY OF  
**SOUTH CAROLINA**

AMENDMENT NO.2 TO SOLICITATION

TO: ALL VENDORS

FROM: Michelle Robinson, CPPB, Procurement Manager

SUBJECT: SOLICITATION NUMBER: USC-RFQ-3102-MR  
Provide Enviro-Tec Fan Coil Units.

DATE: February 22, 2017

---

This Amendment No.2 modifies the Request for Quote only in the manner and to the extent as stated herein.

**VENDORS QUESTIONS AND ANSWERS**

---

BIDDER SHALL ACKNOWLEDGE RECEIPT OF AMENDMENT NO.2 IN THE SPACE PROVIDED BELOW AND RETURN IT WITH THEIR BID RESPONSE. FAILURE TO DO SO MAY SUBJECT BID TO REJECTION.

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Name of Offeror

\_\_\_\_\_  
Date

## **QUESTIONS RECEIVED FROM VENDOR A**

1. **Question 1:** What's the tonnage?

**Answer:** 13,655 btu/hr cooling and 25,775 btu/hr heating

2. **Question 2:** How much CFM?

**Answer:** 467 cfm at 0.25"ESP

3. **Question 3:** Are these supposed to be vertical units?

**Answer:** Vertical hi-rise units. Units cannot exceed 70" due to closet space constraints.

4. **Question 4:** Please provide performance requirements.

**Answer:** Summer: EAT-DB/WB: 76/63F  
LAT-DB/WB: 53/52F

Winter: EAT DB: 70F  
LAT DB 120F

5. **Question 5:** What is the required model of Enviro-Tec?

**Answer:** VHC