



U N I V E R S I T Y O F  
**SOUTH CAROLINA**

AMENDMENT NO.3 TO SOLICITATION

TO: ALL VENDORS

FROM: Kevin Sanders, Procurement Manager

SUBJECT: SOLICITATION NUMBER: USC-IFB-3077-KS  
Provide Interior painting for Columbia Hall Residence Hall

DATE: Feb. 27<sup>th</sup>, 2017

---

This Amendment **No.3** modifies the Best Value Bid only in the manner and to the extent as stated herein. **Change to Scope: Existing Rubber wall base will not be removed as a part of this project. Painting Contractor is to neatly tape off and protect existing rubber wall base, as a part of preparation. Removal of tape and clean up according to project specifications.**

Vendor Questions and answers

---

BIDDER SHALL ACKNOWLEDGE RECEIPT OF AMENDMENT **NO. 3** IN THE SPACE PROVIDED BELOW AND RETURN IT WITH THEIR BID RESPONSE. FAILURE TO DO SO MAY SUBJECT BID TO REJECTION.

---

Authorized Signature

---

Name of Offeror

---

Date

1. Extent of patching on walls. Due to the condition of the walls with the uneven surface left and painted over after the wallpaper was removed the only way to achieve a smooth wall is to skim the entire surface due to the limited time this added step would make the project nearly impossible to complete on time. Can you give some clarification as to what should be patched and what should be painted over?

Uneven wall surface evident from removal of wallcovering to be prepared and painted as other walls without damage. All damage such as holes, cracks, dents, chips to be addressed according to project specifications. We will not be skim coating entire walls, and understand this texture (from wallcovering removal) may be somewhat visible once we are completed painting.

2. You are requiring that portable toilets to be placed on site. Could you designate toilets in the building to be used during construction?

Yes, we will designate toilets in the building that can be used. These must be maintained and kept clean by the contractor for the duration of the project. If at any time during the project the conditions of the toilets are found unacceptable, use of the designated toilets will end, and portable toilets will be required for the remainder of the project at no cost to the University.