

Addendum Three

March 31, 2017

NOTE: The following amendments, additions, and deletions shall be made to the Construction Documents and Contract Documents. Insofar as those documents are at variance with this Addendum, this Addendum shall govern.

Specifications

Item No.      Description

1.              Refer to Specification 230010: On page 230010-6 add Ingenia Technologies, Engineered Air, and TMI Climate Solutions as approved manufacturers for Air Handling Units.

Clarifications

2.              Refer to Drawing M3: Delete General Note 16 regarding the wrapping of ductwork outside of the building in aluminum jacketing. All ductwork outside of the building shall be internally insulated and protected with a composite membrane in accordance with Specification 230500 page 17. Installation of membrane shall be in strict accordance with manufacturer's published instructions.

END OF ADDENDUM