



ADDENDUM NO.: TWO DATE: 7 APRIL 2017

PROJECT TITLE: **REBID: NUTRITION STATION DODIE  
ANDERSON ACADEMIC ENRICHMENT CENTER**  
University of South Carolina  
Columbia, South Carolina

PROJECT NO.: H27-Z302 WTS No. 1627

WRITTEN BY: Gene Bell, AIA, LEED-AP

TO: Prospective Bidders / Plan Holders

---

Addenda are issued prior to execution of Contract. All instructions contained herein shall be reflected in the Contract Sum and this Addendum will be made a part of the Contract Documents, if, as, and when a Construction Contract is awarded.

This Addendum forms a part of the Contract Documents and modifies the original documents dated 20 March 2017, as noted below. Acknowledge receipt of this Addendum in this space provided on the Bid Form. Failure to do so will subject the Bidder to disqualification.

This Addendum consists of 01 pages.

**A. QUESTIONS:**

1. You're requesting a wood counter coiling shutter door, they don't make a fire rated wood shutter door.
  - a. **The coiling counter shutters are not required to be rated. Note that the Wood Shutter is provided in Alternate no. 1. At the base bid, these shutters are steel; see alternate descriptions in the documents and specifications.**
2. Need more information on the Blinds, did not see any existing blinds.
  - a. **Horizontal Louver Blinds shall be Hunter Douglas, Celebrity or equal. 1" aluminum blinds with standard cordlock, color to match existing.**
3. The removal of the operable partition, does it go back to the owner.
  - a. **No, the Owner does not want the partition; it shall be disposed of by the Contractor.**
4. Need more information on detail 5-A3.01 on the awning, how are you planning to keep this straight, that's a lot of weight with 5/8 drywall.
  - a. **Yes, it must be straight, please see note on drawings requiring delegated design by the stud manufacturer for this portion of the awning. The stud manufacturer must consider the weight of all of the elements attached and design the header/awning accordingly.**
5. With the awning having solid blocking how do you wire the fixtures.
  - a. **It will be acceptable to drill a hole through the blocking large enough for a conduit.**
6. Floor covering, there is no spec on CPT 2 is this also supplied by owner.
  - a. **Yes, CPT2 will be a broadloom carpet matching the existing carpeting and will be Owner Furnished, Contractor Installed. (OFCI)**

**END OF ADDENDUM**