

ADDENDUM NUMBER TWO

for
BLATT POOL REPLASTERING – H27-Z320
UNIVERSITY OF SOUTH CAROLINA
COLUMBIA, SOUTH CAROLINA

DATE OF ISSUE: May 12, 2017

TO: ALL BIDDERS OF RECORD

This Addendum is issued pursuant to the Conditions of the Contract and is hereby made part of the Contract Documents. The addendum serves to clarify, revise, and supersede information in the Project Manual, the Drawings, and previously issued Addenda. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form. Failure to do so may subject the Bidder to disqualification. A list of attachments, if any, is part of this document.

BIDDER SHALL ACKNOWLEDGE RECEIPT OF ADDENDUM IN THE SPACE PROVIDED ON THE BID FORM. FAILURE TO DO SO MAY CONSTITUTE AN INFORMALITY IN THE BID.

This addendum consists of 1 page plus the following attachments: N/A

A. GENERAL:

Item No. Description

N/A

B. CHANGES TO TECHNICAL SPECIFICATIONS AND DRAWINGS:

SPECIFICATIONS

Item No. Description

1. **Clarification:** Section 131105, 3.4E, Provide Seamless top Coat as specified.
2. **Clarification:** Review of the Health Code implies that the pool water will need to be in balance prior to occupancy with chlorine content of between 1 to 8 PPM (free chlorine) and pH of 7.0 to 7.8 standard units. Contractor shall provide a written report indicating water balance at project completion per Specification section 131105 part 1.2 C.

DRAWINGS

Item No. Description

1. **Clarification:** Sheet DD-1, Demolition and Construction Note 11. "RELOCATE BULKHEAD AS REQUIRED FOR DEMOLITION AND REPLASTERING OF SWIMMING POOL." The pool bulkhead can be moved within the pool to facilitate the work, contractor's choice.
2. **Revision:** Sheet DD-1, Demolition and Construction Note 18. Delete the following: "CLEAN STAINLESS STEEL GUTTER (BASE BID) . CONTRACTOR TO PROVIDE OWNER A PRICE PER LINEAR FOOT OF ANY DAMAGED GUTTER GRATES AND REPLACE TO MATCH EXISTING." Add the following: "CLEAN STAINLESS STEEL GUTTER, INCLUDING REMOVAL AND REPLACEMENT OF EXISTING POOL MARKERS ON VERTICAL SURFACE (BASE BID) . CONTRACTOR TO PROVIDE OWNER A PRICE PER LINEAR FOOT OF ANY DAMAGED GUTTER GRATES AND REPLACE TO MATCH EXISTING."

END OF ADDENDUM