

ADDENDUM NUMBER THREE

for
BLATT POOL REPLASTERING – H27-Z320
UNIVERSITY OF SOUTH CAROLINA
COLUMBIA, SOUTH CAROLINA

DATE OF ISSUE: May 12, 2017

TO: ALL BIDDERS OF RECORD

This Addendum is issued pursuant to the Conditions of the Contract and is hereby made part of the Contract Documents. The addendum serves to clarify, revise, and supersede information in the Project Manual, the Drawings, and previously issued Addenda. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form. Failure to do so may subject the Bidder to disqualification. A list of attachments, if any, is part of this document.

BIDDER SHALL ACKNOWLEDGE RECEIPT OF ADDENDUM IN THE SPACE PROVIDED ON THE BID FORM. FAILURE TO DO SO MAY CONSTITUTE AN INFORMALITY IN THE BID.

This addendum consists of 1 page plus the following attachments: N/A

A. GENERAL:

1. **Question:** Can a small white tile line be added to accommodate a break point between plaster installs in this dive pool? The Pebble finishes require more care and attention than the older marble finishes. A small tile line would allow for a better finish and much easier application.
Answer: Yes, a 1'x1" or 2"x2" white tile screed lines can be installed to the dive pool. Please remove plaster white coat before installing tile. Submit tile sample to architect for review.
2. **Question:** When installing the racing tile lanes, can we install directly over the old tile lanes if the substrate is in acceptable condition?
Answer: NO. Please remove existing tile and replace with new tile for consistent pool competitive dimensions. This pool is a Certified NCAA competitive pool and the finish dimensions are required to be accurate per the bid documents.
3. **Question:** When chipping out the old plaster finish (All hollow spots and loose areas will be removed) if the existing plaster is in good condition, can these areas be left and bond coated over in lieu of chipping out entire existing plaster shell? We will be applying a bond coat to the entire existing shell before plaster. It bonds with old plaster as well as the Guniting shell.
Answer: This would only be acceptable if the finish dimensions of plaster match flush with new tile, gutter and pool interior fittings.

END OF ADDENDUM