

ADDENDUM NUMBER 1
Tuesday, May 23, 2017

PROJECT: SMITH LABS LIGHTING REPLACEMENT
UNIVERSITY OF SOUTH CAROLINA
STATE PROJECT NO. H34-I369
LEA PROJECT NO. USC-2017-02

This addendum forms a part of the Construction Documents and modifies the original Bidding Documents dated 03.17.2017 as noted below. Acknowledge receipt of this addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

GENERAL:

- G1 Final Addendum: The final addendum for this project will be posted no later than Thursday, May 25th, 2017 at 2:00pm.
- G2 Last Day for Questions: Last day for questions is set Tuesday, May 23rd at 5:00pm. Question shall be submitted in writing to Joe Land via email at Joe.Land.LEA@sc.rr.com.
- G3 Bid Closing: Closing is scheduled for Tuesday May 30th at 2:00pm at 743 Greene Street.
- G4 The Pre-Bid Conference Sign-In Sheet is attached to this addendum (1 page).
- G5 Anyone wishing to visit the project site prior to bid, contact Cody Godfrey at 864/503-5500.

DRAWINGS:

- D1 Drawing E-1 - Lighting Fixture Schedule: The following are prior-approved substitutions for the lighting fixtures specified in the Lighting Fixture Schedule and new additions to the schedule:

Type "A"	Columbia	LCAT24-9-40MLG-EDU	
Type "AE"	Columbia	LCAT24-9-40MLG-EDU	
Type "B"	Columbia	LCS4-40ML-EDU CSWG4	
Type "C"	Columbia	LCAT22-940VL-EDU	(New fixture type - not currently shown in schedule)
Type "C"	H.E. Williams	LT-22-L43/840-AF-DIM-EQCLIPS	(New fixture type - not currently shown in schedule)
Type "U"	Nexus	2-PT18-LD1-IDNA	
- D2 Drawing E-1 - Lighting Fixture Schedule: Change the part number for the Type "U" fixture from PRO-3N-LA-AD to be PRO-3N-LA-ADNA (advanced diagnostic - non-audible).
- D3 Drawing E-2: Room 315 - Provide labor to remove one additional 2' x 4' troffer.
- D4 Drawing E-3:

Room 301: Delete one 2' x 4' Type "A" lighting fixture and replace with one Type "C" 2' x 2' fixture.

Delete the 2' x 4' Type "A" lighting fixture that is turned 90-degrees to the other fixtures in the room and provide two Type "C" lighting fixtures to replace it.

Room 303: Delete one 2' x 4' Type "A" lighting fixture and replace with one Type "C" 2' x 2' fixture.

Delete the 2' x 4' Type "A" lighting fixture that is turned 90-degrees to the other fixtures in the room and provide two Type "C" lighting fixtures to replace it.

Room 304: Delete one 2' x 4' Type "A" lighting fixture and replace with one Type "C" 2' x 2' fixture.

Delete the 2' x 4' Type "A" lighting fixture that is turned 90-degrees to the other fixtures in the room and provide two Type "C" lighting fixtures to replace it.

Room 311: Delete one 2' x 4' Type "A" lighting fixture and replace with one Type "C" 2' x 2' fixture.

Delete the 2' x 4' Type "A" lighting fixture that is turned 90-degrees to the other fixtures in the room and provide two Type "C" lighting fixtures to replace it.

Room 315 - Provide one additional Type "A" lighting fixture in room.

END OF ADDENDUM NUMBER 1

**University of South Carolina
Non Mandatory Pre Bid Sign In Sheet
Spartanburg, SC**

Project Name: Upstate Smith Labs Lighting Replacement
Project Number: H34-1369
Pre Bid Date & Time: May 18, 2017 10AM 155 American Way Conf Rm 110

SWMBE Contractor Indicate Below	Name	Company Name	Address	Phone #	Email
S W M B E	Cody Godfrey	USC upSTATE	800 UNIVERSITY WAY	864-503-5500	Cgodfray@usc.upstate.edu
S W M B E	Joe Land	Land Engineering	262 Sandhurst Rd, Columbia, SC 29210	803 (803) 528-1437	Joe.Land@LEA@SC.PA.COM
S W M B E	Chuck Williams	DNB Electric	PO Box 2296 West Columbia 29171	803-381-2296	Chuck@DNBElectric.com
S W M B E	Aimee Rish	USC	743 Greene St Colum 29208	777-2261	arish@fmc.sc.edu
S W M B E	Lee Miller			777-2834	mille979@mailbox.sc.edu
S W M B E					
S W M B E					
S W M B E					
S W M B E					

***By signing this sheet you agree to receive information electronically.