

USC-Aiken Pacer Downs Hot Water Replacement

Project No.: H29-I353

June 9, 2017

Addendum No. One

1. Confirmation: The bid opening will be on Wednesday, June 14, 2017 @ 2:30pm at 743 Greene Street, Columbia, SC 29208 conference room 53.
2. Locate water heater control modules in the 2nd floor mechanical closet and not at the water heater locations as noted on the drawings.
3. Change requirement for 2" thick pipe insulation to 1" thick.
4. Pre-Bid sign in sheet attached

University of South Carolina
 Pre Bid Sign In Sheet
 Columbia, South Carolina

USC-Aiken Pace Downs Hot
 Water Replacement
 H29-1353
 May 30, 2017 @ 10:00am

Project Name:
 Project Number:
 Pre Bid Date & Time:

SWMBE Contractor?	Name	Company Name	Address	Phone #	Email
<u>SWMBE</u>	Frank Gillies	METRO SURVEYING	151 PRYOR RD COLUMBIA, SC	803-722-0013	FGILLIES@YAHOO.COM
SWMBE	STEVEN PETERSEN	ING CONSULTING	550 11th ST. AUGUSTA, GA 30901	706-774-1020 EXT. 204	SPETERSEN@INGCONSULTING, INC.COM
SWMBE	BRIND ENIER	USC AIKEN			brinden@usca.edu
SWMBE	TROY GRECA	USC COLUMBIA			greca@usc.edu
SWMBE	HATICE HIKMET	USC COLUMBIA			HIKMETH@MAILBOX.USCA.EDU
SWMBE	STAN GLOBE	GLOBE PLUMBING	1 Summit Business Columbia	803-442-4900	STAN@GLOBEPLUMBING.COM
SWMBE	JASON C. CORRELL	CORRELL & COMPANY, INC.	151 WINTERWOOD WAY LEX. SC.	803-256-1570	JCORRELL@CORRELLANDCOMPANY.COM
SWMBE					
SWMBE					

***By signing this sheet you agree to receive information electronically.

CASE DAY = 6/13
 for ?