

**East Energy Facility Lead Abatement
Project Number 50003269
University of South Carolina**

Addendum Number Two

Date: October 17, 2017

From: Aimee B. Rish
Procurement Specialist

To: All Bidders

The following items add to, modify, clarify, or otherwise later the Drawings and/or specifications and will become a part of the Contract Documents. Where a portion of the Drawings and/or specifications is added to, modified, clarified, or otherwise altered, the portion shall not so affected shall remain. Bidder shall include all effects that these items may have on his proposal.

Acknowledgement receipt of this addendum in the space provided on the Bid Form. Failure to do so may subject a Bidder to disqualification.

Questions from the Contractors

- A. Is there 480 (3 phase) in the building that the Contractor is allowed to use to provide them power in the basement, or are they needing to supply a generator?
 - a. USC Will provide a 480 drop but the contractor will need to provide power cables to the equipment

- B. Will the Contractor be allowed to use the existing hoist to lower their heavier equipment down to the basement?
 - b. The Contractor will be allowed to use the hoist but must not exceed the 2-ton limit.

- C. Will the Contractor be required to obtain the work permit?
 - c. No. USC will obtain the on-site work permit.

General Clarifications

1. The closing date is scheduled for Tuesday, October 24, 2017 at 2:00PM at 743 Greene Street Conference Room 053
2. All bids which are hand-delivered or mailed are required to be sent to 743 Greene Street; Columbia, SC 29208. Attn: Aimee Rish "Bid Enclosed 50003269."

End of Addendum Number Two