



**AMENDMENT TO SOLICITATION**

**Amendment No. 1**

**DATE:** December 6, 2017  
**TO:** ALL VENDORS  
**FROM:** Leann Cudd, Procurement Specialist  
**SOLICITATION:** USC-IFB-3234-LC  
**DESCRIPTION:** Furnish, Deliver, & Install Trophy Cases & Receptionist Desk

---

Amendment No. 1 modifies this Invitation for Bids only in the manner and to the extent as stated herein.

**Question & Answers**

1. Page 18 / Item 2.4-A1. indicates Display Case Doors are to be 3/8" tempered glass while Page 18 / Item 2.4-B1 indicates Glass Case Doors are to be 1/2" tempered glass. Please clarify.  
**For the Trophy case glass is to be 3/8" fully tempered glass (glass railing is to be 1/2" tempered glass but there is no glass railing in this scope)**
2. Page 20 / Item 1.2 A. refers to both "Glass for display cases" and "glass for guardrail." Please confirm LOT 2 is for the display cases (and associated glass) and LOT 3 is for the guard rail (and associated glass).  
**There is no guardrail glass in this solicitation. This solicitation is for 3 trophy cases and 1 reception desk.**
3. Please confirm the Guard Rail glass is 1/2" tempered.  
**There is no guardrail glass in this solicitation (glass railing is to be 1/2" tempered glass but there is no glass railing in this scope).**
4. Will separate invoicing be allowed for the delivery and acceptance of the Championship Trophy Case due in mid-February? Or is invoicing only allowed at the completion of the entire project?  
**Yes, can handle progress payments as job moves forward.**
5. Who is responsible for providing and welding the salvaged baluster noted on Drawings A2.01/2 and A2.02/6?  
**USC**
6. Who is responsible for the 3Form Lightbox noted on Drawing A2.03/1?
7. **The 3-Form lightbox is to be provided by the contractor as part of this Trophy Case Project scope of work. Electrical rough-in is to be provided by USC, location is to be coordinated prior to installation.**
8. Who is responsible for the moveable trophy bases?  
**The removable trophy bases are to be part of this Trophy Case Project scope of work and provided by the contractor with the other millwork components. Provide the quantity indicated**
9. Who is responsible for the dimensional brushed aluminum letters throughout?  
**Others. Not in this scope.**

---

Bidder shall acknowledge receipt of Amendment No. 1 in the space provided below and return it with their bid response. Failure to do so may delay award of contract.

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Name of Offeror

\_\_\_\_\_  
Date