

Goodwyn Mills Cawood
1320 Main Street, Suite 300
Columbia, SC 29201

ADDENDUM NO. 1

The following items shall take precedence over the drawings and specifications for the above named project and shall become a part of the contract documents. Where any item called for in the specifications, or indicated on the drawings, is not supplemented hereby, the original requirements shall remain in effect. Where any original item is amended, voided or superseded hereby, the provisions of such item not specifically amended, voided or superseded shall remain in effect.

ATTACHMENTS

Documents:

1. Pre-bid sign in sheet

GENERAL

1. Bidders are hereby advised that information from bid documents which are not received from the sources listed in the Invitation for Bids is not legitimate and the bidder accepts full responsibility for any differences. Goodwyn Mills Cawood has not authorized the scanning of the documents. Bidders should be aware that the plans are copyrighted and any unlawful use is subject to legal action. Bidders are further advised that the purchase and/or use of partial bid documents is not recommended and bidder will be responsible for any discrepancies which might have been avoided had a full set of documents been reviewed.
2. Listing of multiple products or manufacturers within specifications or approval of products or manufacturers via substitution request does not waive or preclude any and all performance, warranty or specific requirements listed within the specification unless specifically noted in the Addendum. Only manufacturers and products meeting the specification requirements and listed in the specifications or included in the Addendum shall be approved for the project.

QUESTIONS:

Item No. Question / Answer

1. Question: Is the Certification requirement noted in Specification Section 08 80 00 (Glazing) required?
The National Glass Association has terminated their certification program
Answer: **A certification by the National Glass Association's Glass Installer Program is NOT required. The Contractor or sub-contractor shall be licensed by the state of South Carolina with the "Glass and Glazing" – "GG" designation. A copy of the license shall be submitted with the Shop drawings.**
2. Question: Can intermediate posts be installed along the run of the glass railing for additional support?
Answer: **In our research and in discussing the design with the Manufacturer of the railing system, no additional supports are or should be necessary. The use of vertical posts may be acceptable if deemed required by the qualified professional engineer signing and sealing the Shop Drawings submittal as noted in paragraph 1.3 (D) – Action Submittals. If deemed required, posts at third points or the use of "Stabilizing End Caps" may be used. The profile shall be square in shape of minimal dimension and in the same plane as the glass. All associated details shall be included in the Shop Drawings for review and Approval by the Architect.**

END of ADDENDUM #1

ADDENDUM #1

**University of South Carolina
Pre Bid Sign In Sheet
Columbia, South Carolina**

Project Name: Glass Guardian Installation - CLA Suite & Trophy Display Renovation
Project Number: H27-Z362
Pre Bid Date & Time: January 23, 2018 at 11:00 AM

SWMBE?	Name	Company Name	Address	Phone #	Email
Yes No	Juaquana Brookins	USC	1300 Pictans Street, Columbia SC 29208	803.777.3596	jbrookin@fmc.sc.edu
Yes No	Lorena Candies	Candies Conit	3792 Ladson Rd Ladson SC 29458	543 296-1991	candiesiii@aol.com
Yes No	Tyler Meyer	First Class Const	126 B Surber Columbia SC 29210	803 926-1922	Tmeyer@fcon.com
Yes No	MARC WAREED	GMC	1320 Main St. Suite 300 Columbia SC 29201	803-724-1282	marc.wareed@gmcwestwork.com
Yes No	A Derrick	USC			
Yes No	Travis Trainum	Trainum Brothers Glass	814 Mitten Dr Clem SC 29412	803-452 1098	Travis@tbsvc.com
Yes No	Jeff Davis	Athletics	1304 Heywood St.	777-0459	jeffd@mailbox.sc.edu
Yes No					
Yes No					

***By signing this sheet you agree to receive information electronically.