

## **ADDENDUM NO. 1**



**REBID – USC Upstate Smith Circle  
Pavement Improvements  
State Project No. H34-I378  
WKD Project No. 20170108.00.CA**

**March 1, 2018**

---

### **TO ALL BIDDERS:**

This Addendum forms a part of the Contract Documents and modifies the Bidding Documents.

Acknowledge receipt of this Addendum in the space provided in the Bid Form. Failure to do so may disqualify the Bidder.

Bidders and other interested parties are informed that the above referenced plans, specifications and contract documents are hereby revised, changed, clarified and supplemented as set forth below:

### **GENERAL / CLARIFICATIONS**

1. A non-mandatory pre-bid meeting was held on 2/28/18 at 10:00 AM. A list of attendees is attached.
2. Deadline for questions is Wednesday 3/7/18 at 4:00 PM. All questions should be directed in writing to the Engineer, Bryan Thomas, PE (WK Dickson) at bthomas@wk dickson.com. Please submit all questions in one email.
3. The final addendum will be issued by Friday 3/9/18 by 3:00 PM.
4. Bids are due on 3/14/18 at 3:00 PM and are to be delivered to the USC (Columbia campus), Facilities Procurement Department, 1300 Pickens Street, Columbia, SC 29208, Attn: Aimee Rish. Bids will then be publicly opened in Conference Room 100C.
5. DO NOT deliver/mail your bid to the USC Upstate campus – all bids must go to the USC Columbia campus.
6. Please ensure the following information is placed on the exterior of the bid envelope: “Bid Enclosed for H34-I378: REBID – USC Upstate Smith Circle Pavement Improvements, Attn: Aimee Rish.”
7. It is the contractor’s responsibility to ensure you are properly licensed for the required work, per LLR licensing requirements, prior to submitting a bid.
8. All third party testing and inspections, including geotechnical services, will be provided by the university and shall not be included in the contractor’s bid.

9. The project contains no bid alternates.
10. Spartanburg County has deemed this project “maintenance” and is not issuing a grading and/or land disturbance permit. CEPSCI (SWPPP) inspections are not required.
11. The asphalt pavement section show in the plans is for both asphalt pavement areas, 1 and 2.
12. Excess millings from asphalt demolition can be deposited on campus, at a location to be determined by the owner.
13. The 18-inch storm drain line running through the circle will need to be potholed during demolition operations to verify the depth at the southeast intersection with the underdrain.
14. A portion of the adjacent parking lot will be provided to the contractor for staging and materials storage. Security of the site will be the contractor’s responsibility.
15. Safety barricades and signage for the site will be required, and will be the contractor’s responsibility.
16. Pavement striping shall be non-thermoplastic.
17. The anticipated start date for construction will be mid-May.
18. Asphalt will not be indexed.
19. Contractor is responsible for notification to SC811 (PUPS) for utility location. USC Upstate will also get a copy of this notification, and will mark all known private utilities in the area.

**PLANS / SPECIFICATIONS:**

1. No Changes.

**ATTACHMENTS:**

1. Pre-Bid sign-in attendance sheet

**END OF ADDENDUM NO. 1**

University of South Carolina  
 Non Mandatory Pre Bid Sign In Sheet  
 Spartanburg, SC

Project Name: REBID USC Upstate Smith Circle Pavement Improvements  
 Project Number: H34-1378  
 Pre Bid Date & Time: February 28, 2018 10:00AM 155 American Way Spartanburg SC

SWMBE Contractor indicate Classification Below	Name	Company Name	Address	Phone #	Email
S W M B E	Godfrey	UPSTATE	500 University Ave	864-503- 5500	Godfrey@usc.upstate.edu
S W M B E	Bryan Thouts	Wick Dickson	1320 Main St Columbia, SC	803-761- 4261	BTADMS@WICKDICKSON.COM
S W M B E	Travis Sparrow	Pavement Applications	P.O. Box 25787 Greenville, SC 29616	864-277- 7860	travis@pavementapplications.com
S W M B E					
S W M B E					
S W M B E					
S W M B E					
S W M B E					
S W M B E					

\*\*\*By signing this sheet you agree to receive information electronically.