

Project Name: Koger Center Catwalk Project
Project Number: FP00000072
University of South Carolina

Addendum Number (2) Two

Date: 22-MAR-2018

From: Aimee Rish, Procurement Specialist

To: All Bidders

The following items add to, modify, clarify, or otherwise later the Drawings and/or specifications and will become a part of the Contract Documents. Where a portion of the Drawings and/or specifications is added to, modified, clarified, or otherwise altered, the portion shall not so affected shall remain. Bidder shall include all effects that these items may have on his proposal.

Acknowledgement receipt of this addendum in the space provided on the Bid Form. Failure to do so may subject a Bidder to disqualification.

GENERAL CLARIFICATIONS/UPDATES:

HAZMAT SURVEY REPORT:

WHITE PAINTED WOODEN HANDRAILS: **NEGATIVE** FOR LEAD
WHITE PAINTED SUPPORT BEAM: **NEGATIVE** FOR LEAD

ASBESTOS HAS NOT BEEN FOUND IN THIS BUILDING. THIS DOES NOT MEAN THAT ASBESTOS DOES NOT EXIST IN THE BUILDING AS ALL BUILDING MATERIALS HAVE NOT BEEN TESTED. FOR FURTHER INFORMATION, PLEASE CONTACT THE USC HAZMAT PROGRAM.

See Attachments:

1. HAZMAT Survey Report - FM00559039

End of Addendum

Description HAZMAT SURVEY - 086

Site	COLUMBIA	Assigned To	SWARREN
Building	086 KOGER CENTER	Crew	HAZMAT
Floor	CATWALK	Start Date	
Room:		Priority	20
Equipment		Due date	
		Request Date	10-OCT-17
		by	CAMOORE

Request #	FM00559039	Description	HAZMAT SURVEY - 086
Parent WO #			

CP Number	FP00000072	KOGER CENTER CATWALK PROJECT
------------------	------------	------------------------------

State/Internal Project Number

Requestor		Project Manager	MERGNER, CHRISTIAN F.
Telephone		Telephone	777-4569
Alternate		Estimated Cost	\$ 100.00
Telephone		Billing	CHARGEBACK-EXT
Non-Available Time		64400-E001-52043 (KOGER CENTER RESTORATION FEE)	

Task List
PLEASE REVIEW AND CONFIRM HAZMAT SURVEY DATA REQUIRED FOR LIMITED WORK AT CATWALK LEVEL, IF NEEDED.

DATE WORK STARTED	CAUSE
DATE WORK COMPLETED	CONDITION
EQUIPMENT	
CLOSING REMARKS	
BENCHSTOCK MATERIALS	
Qty	Description
	Price Per Unit

Supervisor's Approval _____

Note	Date	Title
	20-MAR-18	HAZMAT SURVEY RESULTS
SURVEY DATE:03/20/2018		
INSPECTOR #: SIMONE WARREN (GR00052)		
SCOPE: THE FOLLOWING SURVEY WAS PERFORMED IN PREPARATION FOR A CATWALK EXPANSION PROJECT (CATWALK LEVEL 5) TO IMPACT EXISTING WHITE PAINTED WOODEN HANDRAILS AND GRAY PAINTED METAL SUPPORT BEAM (WHICH HAS NO SPRAYED APPLIED FIREPROOFING). LEAD BASED PAINT WAS THE ONLY CONCERN FOR THIS MINOR PROJECT.		
ASBESTOS SECTION: WOODEN HANDRAILS: NON SUSPECT FOR ASBESTOS METAL SUPPORT BEAM: NON SUSPECT FOR ASBESTOS		
LEAD SECTION: WHITE PAINTED WOODEN HANDRAILS: NEGATIVE FOR LEAD WHITE PAINTED SUPPORT BEAM: NEGATIVE FOR LEAD		

INSPECTORS NOTES:

- IF YOU ENCOUNTER ANY OTHER MATERIALS IN PLACE AND DEEM THEM SUSPECT FOR ASBESTOS AND/OR LEAD, PLEASE STOP WORK AND CONTACT THE ASBESTOS PROGRAM MANAGER FOR FURTHER TESTING OR ABATEMENT.

PLEASE SEE ATTACHMENT FOR XRF SAMPLES.

01-FEB-16 ASBESTOS SUMMARY FOR KOGER CENTER (086) – FEBRUARY 2016

ASBESTOS HAS NOT BEEN FOUND IN THIS BUILDING. THIS DOES NOT MEAN THAT ASBESTOS DOES NOT EXIST IN THE BUILDING AS ALL BUILDING MATERIALS HAVE NOT BEEN TESTED.

FOR FURTHER INFORMATION, PLEASE CONTACT THE USC HAZMAT PROGRAM.