



**USC Upstate - Humidity Control Upgrades at Palmetto House
University of South Carolina Upstate
Spartanburg, SC**

Project # FP00000121

Addendum No. 1

DATE: June 28, 2018

FROM: PERITUS ENGINEERS & ASSOCIATES, INC.

TO: ALL BIDDERS

The following items add to, modify, clarify, or otherwise alter the Drawings and/or specifications and will become a part of the Contract Documents. Where a portion of the Drawings and/or specifications is added to, modified, clarified, or otherwise altered, the portion not so affected shall remain. Bidder shall include all effects that these items may have on his proposal.

Acknowledge receipt of this addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

Pre-Bid Meeting:

1. The attendance sign-in sheet from the non-mandatory prebid conference meeting held Tuesday, 6/26/2018, at 10:00 AM is included as an attachment with this addendum.

Clarifications:

1. Bid closing deadline is 7-10-2018, 2pm eastern standard time, in Columbia, SC. Refer to the SE-311 document in the project manual for specific bid delivery information.
2. Project drawings, project manual, and addendum information can be found online at <http://purchasing.sc.edu>

PERITUS ENGINEERS & ASSOCIATES, INC.

P.O. Box 16598, Greenville, SC 29606 10 E. Dorchester Blvd. Greenville, SC 29605
o. 864-277-8287, f. 864-277-8290, peritus@peritusengineers.com

3. Deadline for written questions via email is 7-2-2018, 5pm eastern standard time. All questions/inquiries shall be emailed to the project engineer, Jody Parker, PE at jparker@peritusengineers.com
4. Final addendum shall be posted before 7-5-2018, 2:00 pm eastern standard time.
5. The existing hot water piping insulation and supply ductwork insulation is fiberglass, and this insulation material is to be disturbed in order to make branch piping connections and install hot water duct coils.

END OF ADDENDUM NO. 1

University of South Carolina
Non Mandatory Pre Bid Sign In Sheet
 Columbia, South Carolina

Project Name: USC Upstate Humidity Control Upgrades at Palmetto House
Project Number: FP00000121
Pre Bid Date & Time: June 26, 2018 10AM 155 American Way Spartanburg SC

SWMBE Contractor Indicate Below	Name	Company Name	Address	Phone #	Email
S W M B E	Andrea Wyman	Johnson Controls	-	864-607-2255	Andrea.Marie.Wyman@jci.com
S W M B E	JAKE SMITH	JCI	—	864-436-7721	donald.j.smith@jci.com
S W M B E	DANIEL HOPPE	JCI	—	864-516-5331	DANIEL.LEE.HOPPE@JCI.COM
S W M B E	Cody Godfrey	USC UPSTATE	—	864-503-5500	Cgodfrey@uscupstate.edu
S W M B E	Jody Parker	Peritus Engineers	—	864-430-9873	jparker@peritusengineers.com
S W M B E					
S W M B E					
S W M B E					
S W M B E					

****By signing this sheet you agree to receive information electronically.