



UNIVERSITY OF SOUTH CAROLINA

AMENDMENT 1 TO SOLICITATION

DATE: October 17, 2018
TO: ALL VENDORS
FROM: Juaquana Brookins, Procurement Officer
SUBJECT: USC-IFB-3378-JB

DESCRIPTION: Provide Service, Repair and Inspection of Fire Detention, Fire Suppression and other Life Safety Systems

This Amendment No.1 modifies the Invitation for Bids only in the manner and to the extent as stated herein.

Question and answers to vendor questions.

OFFERORS SHALL ACKNOWLEDGE RECEIPT OF AMENDMENT 1 IN THE SPACE PROVIDED BELOW AND RETURN IT WITH THEIR BID RESPONSE. FAILURE TO DO SO MAY SUBJECT BID TO REJECTION.

Authorized Signature

Name of Offeror

Date

Questions and Answers

1. Lot (A) pricing uses (1) HR as unit of measure but asks for an estimated on the extended amount, should the per hr rate be extended or do we need to calculate what of the 125k anticipated will be used? **The unit price should be hourly, the \$125,000 is an anticipated amount that we are looking to spend, and the amount may be more or less than anticipated.**
2. Does the Service Manager have to be NICET Level III? **Yes.**
3. What months are the inspection due or are they due throughout the year? **The inspections are due throughout the year with some restrictions for our residence halls which will be between May and June only.**
4. Will we be provided device counts regarding fire alarm, and number of sprinkler systems the University has? **See Exhibit A for fire alarm systems.**
5. Will we need any lifts to test any fire alarm devices? **Yes.**